

MEMO

DATE: November 2, 2015
TO: Governing Body
FROM: Dave McQuarie, MCD Plan Review Sub-Committee Chair
VIA: David A. Chapman, Interim ADA Coordinator/Staff Liaison
RE: City of Santa Fe Removal and Replacement of Decorative Street Lights

As per Resolution 2006-151, the above referenced project was reviewed by myself, Chair of the MCD Plan Review Sub-Committee and David A. Chapman, Interim ADA Coordinator/MCD Staff Liaison on October 29, 2015. Plan comments are as follows:

1. The minimum width for an ADA route is 36 inches; however, the absolute minimum width is 30 inches for a 24 inch run. With the exception of No. 16 at 172 Cienega Street, no other light standard encroaches on the minimum ADA right-of-way. Therefore, if No. 16 is relocated a few inches it should be acceptable per ADA clearance.

Thank you for notifying this committee as to this plan review.

If you have any questions please **call me at 471-5785** as I do not have internet access.

Thank you.

EXC: MCD Members
Rick Devine, Engineering Supervisor, Traffic Preservation Division