



149 Wildlife Way * Santa Fe, NM 87506 * (505) 424-1850
www.sfswma.org

ADDENDUM No. 2
to
RFB No. '15/04/B

Date: August 21, 2014
To: All Bidders of Records
From: Randall Kippenbrock, P.E., Executive Director
Re: RFB No. '15/04/B – Above-Ground Storage Tank Removal and Installation at the Caja del Rio Landfill

This Addendum forms a part of the Contract Documents and modifies or supplements the Specifications as indicated below. All other provisions of the Contract Documents shall remain unchanged. This Addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof. Bidders shall acknowledge receipt of this Addendum in the appropriate space at the end of this Addendum.

Specifications

Page 17

Part 2 - Products

Section 2.5 - Dispensing System

Item A - Submersible pump shall be a 1¾ hp Red Jacket with an anti-siphon valve or equivalent.

Replace the text “1¾ hp” with “1½ hp.”

This Addendum must be signed and returned with your Bid Submittal Form. Failure to do so may cause your bid to be considered non-responsive.

Receipt of Addendum No. 2 to RFB No. '15/04/B is hereby acknowledged

Authorized Signature

Date

Firm Name