

**“Request For Bids” – FY 14/15 DOUGLAS ST., MILLER ST., CAMINO ESCONDIDO
WATER MAIN REPLACEMENT, CIP #3046
RFB #15/22/B**

April 1, 2015

Addendum No. 1 – Clarifications and answers to questions following the Pre-Bid Conference held March 31, 2015.

Project Manager & Water Division Engineer: Eric Ulibarri, (505) 955-4279

Question 1: Will compaction tests be required?

Answer: Please refer to the City of Santa Fe Public Utilities Department Water Division Construction Standards and Specifications Page 3, Section A.11.

Question 2: Will construction permits be required or will permit requirements be waived by the City?

Answer: Construction Permits will be required as indicated in the City of Santa Fe Public Utilities Department Water Division Construction Standards and Specifications Page 2 (Section A.8), Page 3 (Section A.10.3) and Page 5 (Section B.2).

Question 3: Will vibration monitoring and/or a video/photo survey be required by the contract?

Answer: The City of Santa Fe will not require vibration monitoring or pre-construction video/photo surveys of the construction sites.

Question 4: What are the City of Santa Fe Potability Requirements for this project?

Answer: Please refer to the City of Santa Fe Public Utilities Department Water Division Construction Standards and Specifications Standard Detail, Page 1, ‘General Notes’, Note 11.

Question 5: Will water be available on the project site?

Answer: Water shall not be accessed from local fire hydrants for construction activities. Such uses shall use effluent from the City’s Treated Wastewater Dispensing Station. Please visit:

http://www.santafenm.gov/purchase_reclaimed for requirements and fees.