

**“Request for Bids” – FY 15/16 OLD FILTER PLANT, DEMPSEY BOOSTER STATION, AND 5MG TANK SITE IMPROVEMENTS PROJECT CIP # 3041A**

---

**RFB #15/31/B**

June 18, 2015

**Addendum No. 2 – Clarification on dimensions of Meter Vault.**

Project Manager & Water Division Engineer: Eric Ulibarri, (505) 955-4279

There is a discrepancy between the dimensions shown on Plan Sheet (6 of 6) and the description for Bid Item No. 120 on page 110 of the contract documents. The inside dimensions of the meter vault shall be 8' x 10' x 6'.