

February 12, 2016
NOTE TO BIDDER'S
ADDENDA #4 to RFB # '16/24/B
CN:2100280 SANTA FE RIVER TRAIL CONNECTION AND IMPROVEMENTS PROJECT

Please be advised of the following questions and answers from the (mandatory) pre-bid meeting held on February 2, 2016:

Question 1. The sidewalk and rail typical section on Sheet 2-6 specifies the posts at 8' maximum but the standard drawing shows 10' maximum.

Answer 1. On the plan set, sheet 2-6 should be read 10' maximum.

Question 2. How many Portable Changeable Message Signboards are needed?

Answer 2. Two (2) message signboards are needed for this project. The bidder shall bid on the item #702610 - Portable Changeable Message Sign by the unit EA (Each).

Question 3. The pedestrian rail is to be built per STD DRAWING 607-20-1/4 THRU 3/4; however, the pay items used are 543100 and 543200, which are bridge items. What was the reason that Section 543 items were used?

Answer 3. Section 543 was used to differentiate the two types of rail and to cover the structural items needed for the bicycle rail.

Question 4. What is the difference between pedestrian railing and bicycle railing that the pedestrian railing item 543100 has a hand rail and the bicycle railing item 543200 does not?

Answer 4. Pedestrian railing is 3'6" high with a handrail. Bicycle railing is 4'6" high without a handrail.

Question 5. For rigid electrical conduit, please clarify if metallic or PVC. Any deviation from Section 790.3.1?

Answer 5. No deviation from specification. Underground installation is supposed to be non-metallic.

Question 6. For the boring of conduit, please clarify if a sleeve is needed.

Answer 6. Sleeve is not needed for boring.

Question 7. Is this bid an A + B Bid?

Answer 7. No, the contract will be awarded to the lowest bidder.

All other pertinent information to remain the same.

RECEIPT ACKNOWLEDGE BY PROPONENT

This addendum will be part of the bid documents and shall be included with the bid submittal. Non-receipt of addenda by the bidder in no way relieves bidder of obligation of compliance with any terms and conditions stated in the addenda.